




Renewable Energy & Hydroelectric Works

Exercise instructions: Design of Small Hydroelectric Power Plants



Nikos Mamassis, Andreas Efstratiadis, Demetris Koutsoyiannis and Sandra Baki
Department of Water Resources & Environmental Engineering, School of Civil Engineering, NTUA, Academic year 2018-19

Exercise

The construction of a small hydropower plant with a net head of 260 m is considered in a specific river location. Daily flow data are available at the location of the intake for a period of 10 hydrologic years (Excel file), whereas Table 1 contains the corresponding values of the mean monthly flows.

Table 1 Mean Monthly Flows (m³/s)

Month	10	11	12	1	2	3	4	5	6	7	8	9	Annual
Mean value	0.48	1.37	1.46	0.99	1.40	1.53	1.66	1.03	0.42	0.23	0.15	0.12	0.90

Requested:

1. The estimation of the environmental flow and the timeseries of the daily volume of water exploitable for hydropower production
2. The initial estimation of the mean annual potential electrical energy, assuming a total efficiency of 0.85
3. The development of the exploitable daily flow duration curve
4. The development of a spreadsheet for the simulation of the hydropower plant's daily operation and the calculation of the electricity produced. Assume that the turbine starts operating with a flow higher than 10% of the maximum flow and has a **constant total efficiency** of 0.85. Considering that one turbine is going to be installed, estimate its nominal flow, so that the production of electrical energy is maximised.
5. The development of a spreadsheet for the simulation of the hydropower plant's daily operation and the calculation of the electricity produced. Assume that the turbine has a **variable efficiency** (that can be estimated via the curves supplied), whereas the efficiency of the electromechanical equipment is 0.96. Considering that one turbine is going to be installed, estimate its nominal flow, so that the production of electrical energy is maximised. Use the performance curves of the three turbine types (Francis, Pelton, Kaplan), which are supplied in the Excel file. Assume that the following conditions will need to apply: a) the volume of water utilised, after the deduction of the environmental flow, needs to be at least 75% of the total, and b) the exploitation index of the plant needs to be at least 30%
6. Investigate the installation of two turbines. Calculate the electrical energy produced from different turbine combinations and identify the most efficient ones in terms of electricity production
7. The final selection of **two** turbines, after taking into account other factors besides the maximisation of electrical energy production

1. Environmental flow estimation

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1															
2	Έκταση	42.8 km2													
3	Απορροή	28.4 hm3													
4	Απορροή	663.3 mm													
5															
6															
7		10	11	12	1	2	3	4	5	6	7	8	9	Έτος	
8	1971-72	0.18	0.77	1.32	1.02	1.73	1.78	1.55	1.00	0.31	0.21	0.13	0.08	0.84	
9	1972-73	1.20	1.17	0.59	1.43	2.61	2.14	1.74	0.91	0.28	0.11	0.05	0.09	1.03	
10	1973-74	0.32	0.81	1.13	0.20	1.89	1.71	2.17	1.57	0.42	0.11	0.07	0.17	0.88	
11	1974-75	0.90	2.81	1.57	0.76	1.54	1.92	1.06	0.67	0.43	0.15	0.15	0.09	1.00	
12	1975-76	0.77	3.45	2.22	1.11	0.44	2.45	3.62	2.18	0.76	0.22	0.12	0.12	1.45	
13	1976-77	0.22	0.94	1.99	1.05	0.87	1.45	0.99	0.42	0.49	0.32	0.11	0.08	0.74	
14	1977-78	0.18	1.19	0.89	1.80	1.95	1.40	0.98	0.72	0.39	0.40	0.14	0.11	0.85	
15	1978-79	0.57	0.63	0.82	0.39	0.53	0.31	1.28	0.26	0.16	0.09	0.26	0.10	0.45	
16	1979-80	0.15	0.80	3.67	1.88	2.13	1.49	1.37	1.32	0.42	0.48	0.41	0.30	1.20	
17	1980-81	0.28	1.16	0.40	0.28	0.34	0.61	1.80	1.28	0.57	0.18	0.10	0.05	0.59	
18	Μέση τιμή	0.48	1.37	1.46	0.99	1.40	1.53	1.66	1.03	0.42	0.23	0.15	0.12	0.90	
19															
20	ΟΙΚΟΛΟΓΙΚΗ 1		0.08												
21	ΟΙΚΟΛΟΓΙΚΗ 2		0.06												
22	ΟΙΚΟΛΟΓΙΚΗ 3		0.03												
23															
24	ΟΙΚΟΛΟΓΙΚΗ		0.08												
25	V hm3		25.9												
26	75%*V		19.4												
27															
28		0.90	0.08	0.82											
29															
30	1/10/1971	0.17	0.08	0.09											
31	2/10/1971	0.17	0.08	0.09											
32	3/10/1971	0.17	0.08	0.09											
33	4/10/1971	0.15	0.08	0.07											
34	5/10/1971	0.12	0.08	0.04											

Estimation of environmental flow as the maximum of:
 1. 30% of the mean discharge of summer months (June, July, August) or
 2. 50% of the mean discharge of September or
 3. 30 lt/sec in any case.

Flow duration curve
 1. Ranking daily discharges in descending order
 2. Calculation of empirical probability of exceedance

SB1


Slide 3

SB1

"Flow duration curve" instead of "duration curve" or "Flow duration curve for hydropower production"

Sandra Baki, 28/3/2019

2.Initial estimations



*Mean discharge available for hydropower exploitation: **0.82 m/s** (the environmental flow has been abstracted)*

*Mean annual water volume available for hydropower exploitation: **25.9 hm³***

Assuming:

ρ 1000 kg/m³

g 9.81 m/s²

H 260 m

n 0.85

Potential values assuming complete exploitation:

Mean annual energy produced: **15 624 MWh**

Installed power for continuous operation: **1.8 MW**

Installed power for operation of 3000 h: **5.2 MW**

2. Initial estimations

Mean discharge available for exploitation: **0.82 m/s**

Mean annual water volume available for exploitation: **25.9 hm³**

ρ 1000 kg/m³

g 9.81 m/s²


H 260 m

n 0.85


Discharge–installed power relationship

Q (m ³ /s)	I (MW)
0.5	1.1
1	2.2
1.5	3.3
2	4.3
2.5	5.4
3	6.5
4	8.7
5	10.8
10	21.7



Volume percentage–discharge relationship



Volume-time percentage relationship



3. Daily flow duration curve





4. Examples with 1 turbine ($n=0.85$, $Q_{min}=0.2*Q_{max}$)

Theoretical power for various discharges

Data	Q (m ³ /s)	I (MW)
H=260 m	0.5	1.1
$\rho=1000$ kg/m ³	1	2.2
$g=9.81$ m/s ²	1.5	3.3
$n=0.85$	2	4.3
	2.5	5.4
	3	6.5
	4	8.7
	5	10.8
	10	21.7

Warning: In exercise $Q_{min}=0.1*Q_{max}$



Legend

Q_{min}, Q_{max}:

Minimum, maximum exploitation discharge (m³/s)

I_{max}: Power at maximum exploitation discharge (MW)

PT : Percentage of operational time in a typical year (%)

PV: Percentage of water volume used (%)

E: Total annual electrical energy produced (GWh/y)

4. Calculations for 1 turbine

	A	B	C	D	E	F	G	H	I
1									
2				Daily timeseries statistics (a) discharge, (b) water volume, (c) potential energy and (d) required power					
3									
4	H	260		For 10 years	m ³ /s	m ³ /day	kWh	kW	
5	ρ	1000		Maximum	12.1	1045256.9	629479.8	26228.3	
6	g	9.81		Minimum	0	0	0	0	
7	n	0.85		Mean	0.822	71029.3	42775.6	1782.3	
8									
9						hm ³	GWh		
10				Total		259.5	156.3		
11				Total days	3653				
12				Mean annual		25.9	15.6		
13				Daily electrical energy E(kWh)=g*n*H(m)*V(m³)/3600					
14				=B\$6*B\$7*B\$4*C25/3600					
15									
16	Max-Min exploitation discharge (m³/s)					Qmax (m3/s)	10	5	2
17						Qmin (m3/s)	1	0.5	0.2
18	Power at max exploitation discharge (MW)					I _{max} (MW)	21.7	10.8	4.3
19	Percentage of operational time per year (%)					PT (%)	29.9	44.7	61.7
20	Percentage of water volume used (%)					PV (%)	76.9	88.6	80.6
21	Total electrical energy (GWh)					E (GWh)	120.2	138.4	126.0
22						E (GWh/y)	12.0	13.8	12.6
23						ΣΔ	0.06	0.15	0.33
24		m3/s	m3/day	kWh	kW		kWh/d	kWh/d	kWh/d
25	1/10/1971	0.094	8153.6	4910.3	204.6		0	0	0
26	2/10/1971	0.094	8153.6	4910.3	204.6		0	0	0
27	3/10/1971	0.094	8153.6	4910.3	204.6		0	0	0
28	4/10/1971	0.069	5941.2	3577.9	149.1		0	0	0
	Daily volume (m³)		=B25*86400		=D25/24		Daily power I(kW)=E(kWh)/24h		

Data-Constants

Data-daily discharge timeseries

4. Calculations for 1 turbine

	A	B	C	D	E	F	G	H	I
1									
2									
3									
4	H	260							
5	ρ	1000							
6	g	9.81							
7	n	0.85							
8									
9									
10									
11									

- If the daily discharge is within the operational range (minimum-maximum discharge), then the **daily energy** is calculated using the formula

$$E(\text{kWh}) = g \cdot n \cdot H(\text{m}) \cdot V(\text{m}^3) / 3600 = g \cdot n \cdot H(\text{m}) \cdot Q(\text{m}^3/\text{s}) \cdot 86400 / 3600 = g \cdot n \cdot H(\text{m}) \cdot Q(\text{m}^3/\text{s}) \cdot 24$$
- If the daily discharge is greater than the nominal (maximum) one, then the **daily energy** is calculated with a discharge equal to the nominal one.
- If the daily discharge is lower than the minimum operational, then the **daily energy is equal to zero**

```
=IF(AND($B25>G$17,$B25<G$16),$B$4*$B$6*$B$7*$B25*24,IF($B25>G$16,$B$4*$B$6*$B$7*G$16*24,0))
```

						Min and max operational discharge are defined by the user			
16	Max-Min exploitation discharge (m ³ /s)				Qmax (m3/s)	10	5	2	
17					Qmin (m3/s)	1	0.5	0.2	
18	Power at max exploitation discharge (MW)				Imax (MW)	21.7	10.8	4.3	
19	Percentage of operational time per year (%)				PT (%)	29.9	44.7	61.7	
20	Percentage of water volume used (%)				PV (%)	76.9	88.6	80.6	
21	Total electrical energy (GWh)				E (GWh)	120.2	138.4	126.0	
22					E (GWh/y)	12.0	13.8	12.6	
23					ΣΔ	0.06	0.15	0.33	
24		m3/s	m3/day	kWh	kW		kWh/d	kWh/d	kWh/d
25	1/10/1971	0.094	8153.6	4910.3	204.6		0	0	0
26	2/10/1971	0.094	8153.6	4910.3	204.6		0	0	0
27	3/10/1971	0.094	8153.6	4910.3	204.6		0	0	0
28	4/10/1971	0.069	5941.2	3577.9	149.1		0	0	0

4. Calculations for 1 turbine

	A	B	C	D	E	F	G	H	I
1									
2									
3									
4	H	260							
5	ρ	1000							
6	g	9.81							
7	n	0.85							
8									
9							hm ³	GWh	
10				ΑΘΡΟΙΣΜΑ			259.5		
11				Total number of days	3653				
12				Mean annual			25.9		
13									
14									
15									
16	Max-Min exploitation discharge (m³/s)					Qmax (m3/s)	10	5	2
17						Qmin (m3/s)	1	0.5	0.2
18	Power at max exploitation discharge (MW)					Imax (MW)	21.7	10.8	4.3
19	Percentage of operational time per year (%)					PT (%)	29.9	44.7	61.7
20	Percentage of water volume used (%)					PV (%)	76.9	88.6	80.6
21	Total electrical energy (GWh)					E (GWh)	120.2	138.4	126.0
22						E (GWh/y)	12.0	13.8	12.6
23						ΣΔ	0.06	0.15	0.33
24		m3/s	m3/day	kWh		kW		kWh/d	kWh/d
25	1/10/1971	0.094	8153.6	4910.3		204.6		0	0
26	2/10/1971	0.094	8153.6	4910.3		204.6		0	0
27	3/10/1971	0.094	8153.6	4910.3		204.6		0	0
28	4/10/1971	0.069	5941.2	3577.9		149.1		0	0

Calculation of the water volume percentage exploited

- The energy produced is summed
- The daily water volume is calculated (and summed for the entire time period) using the formula: $V(m^3)=Q (m^3/s)*t (hr)*3600=E(kWh)/[g*n*H(m)]=>$
 $V(m^3)=E(kWh)/[g*n*H(m)*3600]$
- This is divided by the total water volume and the percentage is calculated


$$=(SUM(G25:G3677)*3600/(B4*B6*B7))/(F10*1000000)*100$$

Calculation of the operational time in the year

The days in which energy was produced are counted and the percentage is calculated considering the total number of days

$$=COUNTIF(G25:G3677,">0")/E11*100$$

4. Examples with 1 turbine ($n=0.85$, $Q_{min}=0.1*Q_{max}$)




Nominal discharge range, for which the percentage of operational time is greater than 30%

Nominal operational discharge for maximization of the produced energy (use of solver)

16	Qmax (m3/s)	10	5	2	4.49
17	Qmin (m3/s)	1	0.5	0.2	0.449
18	imax (MW)	21,7	10,8	4,3	9,7
19	PT (%)	29,9	44,7	61,7	46,6
20	PV (%)	76,9	88,6	80,6	89,0
21	E (GWh)	120,2	138,4	126,7	139,1
22	E (GWh/y)	12,0	13,8	12,6	13,9
23	ΣΔ	0,06	0,15	0,33	0,16
24		kWh/d	kWh/d	kWh/d	kWh/d
25		0	0	0	0
26		0	0	0	0
27		0	0	0	0
28		0	0	0	0
29		0	0	0	0
30		0	0	0	0
31		0	0	0	0
32		0	0	0	0
33		0	0	0	0
34		0	0	0	0
35		0	0	0	0
36		0	0	0	0
37		0	0	0	0
38		0	0	0	0
39		0	0	0	0
40		0	0	0	0
41		0	0	0	0
42		0	0	11064,63	0
43		0	0	0	0
44		0	0	0	0
45		0	0	0	0


Βέλτιστη λύση με 1 στροβίλο
 $Q_{min}=0.1*Q_{max}$
Q=4.49 m³/s
E=13.9 GWh/y

Solver Parameters dialog box showing: Set Objective: \$J\$21, To: Max, By Changing Variable Cells: \$J\$16, Subject to the Constraints: (empty), Make Unconstrained Variables Non-Negative, Select a Solving Method: GRG Nonlinear, Solve button.



Nominal discharge range, for which the percentage of water volume used is greater than 75%


Energy production curve for nominal discharge in the range 1-12 m^3/s



5. Turbine efficiency curves


- Assuming an efficiency for the electromechanical equipment of **0.96**,
- the total efficiency of **0.85** corresponds to:
- a turbine efficiency of $0.85/0.96=$ **0.885**

Q/Qmax	Francis ns=100	Pelton ns=21	Kaplan ns=650
10	0,3	0,78	0,08
20	0,6	0,86	0,78
30	0,77	0,88	0,87
40	0,82	0,89	0,91
50	0,85	0,89	0,93
60	0,88	0,89	0,94
70	0,91	0,89	0,94
80	0,93	0,89	0,94
90	0,94	0,89	0,94
100	0,93	0,89	0,93




	Francis ns=100	Pelton ns=21	Kaplan ns=650
0	0	0	0
1	1	1	1
2	2	2	2
3	3	3	3
4	4	4	4
5	5	5	5
6	6	6	6
7	7	7	7
8	8	8	8
9	9	9	9
10	0,3	0,78	0,08
11	0,33	0,788	0,115
12	0,36	0,796	0,122
13	0,39	0,804	0,129
14	0,42	0,812	0,136
15	0,45	0,82	0,143
16	0,48	0,828	0,15
17	0,51	0,836	0,157
18	0,54	0,844	0,164
19	0,57	0,852	0,171
20	0,6	0,86	0,178
21	0,617	0,862	0,1789
22	0,634	0,864	0,1798
23	0,651	0,866	0,1807
24	0,668	0,868	0,1816
25	0,685	0,87	0,1825
26	0,702	0,872	0,1834
27	0,719	0,874	0,1843
28	0,736	0,876	0,1852
29	0,753	0,878	0,1861
30	0,77	0,88	0,187
31	0,775	0,881	0,1874
32	0,78	0,882	0,1878
33	0,785	0,883	0,1882
34	0,79	0,884	0,1886
35	0,795	0,885	0,189
36	0,8	0,886	0,1894
37	0,805	0,887	0,1898
38	0,81	0,888	0,1902
39	0,815	0,889	0,1906
40	0,82	0,89	0,191
41	0,823	0,89	0,1912
42	0,826	0,89	0,1914
43	0,829	0,89	0,1916
44	0,832	0,89	0,1918
45	0,835	0,89	0,192
46	0,838	0,89	0,1922
47	0,841	0,89	0,1924
48	0,844	0,89	0,1926
49	0,847	0,89	0,1928
50	0,85	0,89	0,193
51	0,853	0,89	0,1931
52	0,856	0,89	0,1932
53	0,859	0,89	0,1933
54	0,862	0,89	0,1934
55	0,865	0,89	0,1935
56	0,868	0,89	0,1936
57	0,871	0,89	0,1937
58	0,874	0,89	0,1938
59	0,877	0,89	0,1939
60	0,88	0,89	0,194
61	0,883	0,89	0,194
62	0,886	0,89	0,194
63	0,889	0,89	0,194
64	0,892	0,89	0,194
65	0,895	0,89	0,194
66	0,898	0,89	0,194
67	0,901	0,89	0,194
68	0,904	0,89	0,194
69	0,907	0,89	0,194
70	0,91	0,89	0,194
71	0,912	0,89	0,194
72	0,914	0,89	0,194
73	0,916	0,89	0,194
74	0,918	0,89	0,194
75	0,92	0,89	0,194
76	0,922	0,89	0,194
77	0,924	0,89	0,194
78	0,926	0,89	0,194
79	0,928	0,89	0,194
80	0,93	0,89	0,194
81	0,931	0,89	0,194
82	0,932	0,89	0,194
83	0,933	0,89	0,194
84	0,934	0,89	0,194
85	0,935	0,89	0,194
86	0,936	0,89	0,194
87	0,937	0,89	0,194
88	0,938	0,89	0,194
89	0,939	0,89	0,194
90	0,94	0,89	0,194
91	0,939	0,89	0,1939
92	0,938	0,89	0,1938
93	0,937	0,89	0,1937
94	0,936	0,89	0,1936
95	0,935	0,89	0,1935
96	0,934	0,89	0,1934
97	0,933	0,89	0,1933
98	0,932	0,89	0,1932
99	0,931	0,89	0,1931
100	0,93	0,89	0,193

5. Example with 1 turbine (with efficiency)




Nominal discharge range, for which the percentage of operational time is greater than 30%



Nominal discharge range, for which the percentage of water volume used is greater than 75%

Energy production curve for nominal discharge in the range 1-12 m³/s



Constant efficiency n=0.85

Q=4.4 m³/s E=13.9 GWh/y

Pelton

Q=4.2 m³/s E=13.8 GWh/y

Kaplan

Q=3.4 m³/s E=13.6 GWh/y

Francis

Q=3.0 m³/s E=12.8 GWh/y

6. Examples with 2 turbines ($n=0.85$, $Q_{min}=0.2*Q_{max}$)


Warning: In exercise $Q_{min}=0.1*Q_{max}$

Data

H=260 m
 $\rho=1000 \text{ kg/m}^3$
 $g=9.81 \text{ m/s}^2$
 $n=0.85$

Theoretical power for various discharges

Q (m ³ /s)	I (MW)
0.5	1.1
1	2.2
1.5	3.3
2	4.3
2.5	5.4
3	6.5
4	8.7
5	10.8
10	21.7



Legend

Q_{min} , Q_{max} :


Minimum, maximum exploitation discharge (m³/s)

I_{max} : Power at maximum exploitation discharge (MW)

PT : Percentage of operational time in a typical year (%)

PV: Percentage of water volume used (%)

E: Total annual electrical energy produced (GWh/y)



6. Examples with 2 turbines ($n=0.85$, $Q_{min}=0.2*Q_{max}$)


Warning: In exercise $Q_{min}=0.1*Q_{max}$

Data

H=260 m
 $\rho=1000 \text{ kg/m}^3$
 $g=9.81 \text{ m/s}^2$
 $n=0.85$

Theoretical power for various discharges

Q (m ³ /s)	I (MW)
0.5	1.1
1	2.2
1.5	3.3
2	4.3
2.5	5.4
3	6.5
4	8.7
5	10.8
10	21.7



Legend

Q_{min} , Q_{max} :


Minimum, maximum exploitation discharge (m³/s)

I_{max} : Power at maximum exploitation discharge (MW)

PT : Percentage of operational time in a typical year (%)

PV: Percentage of water volume used (%)

E: Total annual electrical energy produced (GWh/y)



6. Optimization with 2 turbines ($n=0.85$ for $Q_{\min}=0.1*Q_{\max}$)

	Optimization with 1 turbine	Optimization with 2 same turbines	Optimization with 2 sequential turbines
	$Q_{1\min}=0.1*Q_{1\max}$	$Q_{1\min}=0.1*(Q_{2\max}/2)$	$Q_{1\min}=0.1*0.1*Q_{2\max}$
Q_{\max} (m ³ /s)	4,49	5,08	8,71 = $Q_{1\max}+Q_{2\max}$
Q_{\min} (m ³ /s)	0,45	0,25	0,09 = $Q_{1\min}$
I_{\max} (MW)	9,7	11,0	18,9 (16.9 and 2 MW)
PT (%)	46,6	56,4	75,8
PV (%)	89,0	93,8	99,0
E (GWh)	139,1	146,6	154,7
E (GWh/y)	13,9	14,7	15,5
$\Sigma\Delta$	0,16	0,15	0,09

Theoretical power for various discharges

DATA

$H=260$ m
 $\rho=1000$ kg/m³
 $g=9.81$ m/s²
 $n=0.85$

Q (m ³ /s)	I (MW)
0.5	1.1
1	2.2
1.5	3.3
2	4.3
2.5	5.4
3	6.5
4	8.7
5	10.8
10	21.7

6. Optimization with 2 turbines (considering efficiency curves)

We make the assumption, that initially the first turbine starts operating and in the case that the discharge is out of its operational range, then the flow is routed to the second turbine

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	H	260																
2	ρ	1000					Καμπύλη 1		Καμπύλη 2									
3	ξ	9,81					Q/Qmax	n	Q/Qmax	n								
4	n	0,96	ΣΑ Ηλεκτρομηχανολογικού εξοπλισμού				0		0									
5							1		1									
6	Για 10 έτη	m3/s					2		2									
7	ΜΕΓΙΣΤΟ	12,1					3		3									
8	ΕΛΑΧΙΣΤΟ	0					4		4									
9	ΜΕΣΟ	0,822					5		5									
10							6		6									
11		hm3					7		7			Σύνολο						
12	ΑΘΡΟΙΣΜΑ	259,5		229,2	30,3	19,9	8		8			Qmax (m3/s)		3,80				
13	Σύνολο ημερών	3653					9		9			Qmin (m3/s)		0,04				
14							10		10			E (GWh/y)		13,9				
15	Μέσο ετήσιο	25,9					11	0,33	11	0,33								
16			Στρόβιλος 1		Στρόβιλος 2		12	0,36	12	0,36			Στρόβιλος 1			Στρόβιλος 2		
17			Qmax (m3/s)	3,40	0,40		13	0,39	13	0,39		Qmax (m3/s)	3,40		0,40			
18			Qmin (m3/s)	0,34	0,04		14	0,42	14	0,42		Qmin (m3/s)	0,34		0,04			
19							15	0,45	15	0,45		E (GWh)	12,8		1,1			
20							16	0,48	16	0,48								
21							17	0,51	17	0,51								
22							18	0,54	18	0,54								
23							19	0,57	19	0,57								
24							20	0,6	20	0,6								
25							21	0,617	21	0,617								
26			Παροχές Σ1	Υπόλοιπο	Παροχές Σ2		22	0,634	22	0,634		kWh/d	Q/Qmx	ΣΑ	kWh/d		kWh/d	Q/Qmx
27	1/10/1971	0,094	0,000	0,094	0,094		23	0,651	23	0,651		0,0	1	0,00	0,0		5545,8	23
28	2/10/1971	0,094	0,000	0,094	0,094		24	0,668	24	0,668		0,0	1	0,00	0,0		6545,8	23
29	3/10/1971	0,094	0,000	0,094	0,094		25	0,685	25	0,685		0,0	1	0,00	0,0		5545,8	23

=B27-D27

=\$B\$1*\$B\$3*\$B\$4*\$D27*24

Allocation of discharge to 2 turbines

=IF(AND(\$E27>F\$18;\$E27<F\$17);\$E27;IF(\$E27>F\$17;F\$17;0))

=IF(AND(\$B27>D\$18;\$B27<D\$17);\$B27;IF(\$B27>D\$17;D\$17;0))

=\$B\$1*\$B\$3*\$B\$4*\$F27*24

7. Optimization with 2 turbines (considering efficiency curves)

We make the assumption, that initially the first turbine starts operating and in the case that the discharge is out of its operational range, then the flow is routed to the second turbine

2 Pelton turbines

Qmax (m³/s)	4,2	4,2		4,2		4,2	
E (GWh/y)	13,8	14,6		14,9		15,1	
		Σ1	Σ2	Σ1	Σ2	Σ1	Σ2
Q_{1,2}max (m³/s)		2,1	2,1	3,0	1,2	3,8	0,4
E_{1,2} (GWh/y)		12,7	1,8	13,6	1,3	13,8	1,3

2 Francis turbines

Qmax (m³/s)	3,0	3,0		3,0		3,0	
E (GWh/y)	12,9	14,2		14,0		13,9	
		Σ1	Σ2	Σ1	Σ2	Σ1	Σ2
Q_{1,2}max (m³/s)		1,5	1,5	2,0	1,0	2,7	0,3
E_{1,2} (GWh/y)		11,2	3,0	12,3	1,7	12,8	1,0

Pelton-Francis Combination

Qmax (m³/s)	3,0		3,0		3,0		3,0		3,0		3,0	
E (GWh/y)	14,3		14,1		14,2		14,1		14,4		14,0	
	Pelton	Francis	Francis	Pelton	Pelton	Francis	Francis	Pelton	Pelton	Francis	Francis	Pelton
Q_{1,2}max (m³/s)	1,5	1,5	1,5	1,5	2,0	1,0	2,0	1,0	2,5	0,5	2,5	0,5
E_{1,2} (GWh/y)	11,4	3,0	11,2	2,9	12,6	1,7	12,3	1,7	13,2	1,1	12,7	1,2