Renewable Energy & Hydroelectric Works

Exercise instructions: Use of renewables sources in the energy mix

The energy mix for the production of electrical energy on an island with a population of 1000 is being designed. It has been decided to prioritise the use of renewable sources of energy and only use fossil fuels in case of emergencies. In particular, the following options are considered:

- the installation of wind turbines with power of 500 and 850 kW
- the installation of a photovoltaic station with power of 100 kW
- the installation of a biomass combustion unit, with a thermal power of 4 kWh/kg and efficiency of 40%
- the construction of a pumped storage scheme, with an elevation difference of 100 m, combined efficiency of 88% and hydraulic losses of 5%.

The following are requested:

- 1. the required annual electrical energy, the minimum total power that needs to be installed and the capacity factor of the entire system
- 2. the characteristics of the energy balance on an hourly basis (the produced and the discarded energy, the failure rate in meeting demand) for various combinations of installed wind turbines and photovoltaic stations
- 3. the required quantity for biomass and fossil fuels, so that the energy deficits are completely covered
- 4. the required mean annual water inflow in the pumped storage scheme, that results in the maximum possible coverage of energy deficits and surpluses

The following are provided in the Excel file:

- Hourly 10-year timeseries of wind speed, solar radiation and estimated electric energy demand
- Characteristic quantities of wind turbines and photovoltaic stations

Nikos Mamassis, Andreas Efstratiadis, Demetris Koutsoyiannis and Sandra Baki Department of Water Resources & Environmental Engineering, School of Civil Engineering, NTUA, Academic year 2018-19 Hourly time series

Available Data



1. Electric energy demand



Hourly electric energy demand (MW)



2.1 Estimation of wind energy production



Estimation of wind velocity at the altitude of wind turbine

Roughness length, z_0 , is a corrective measure to account for friction effects to wind flow due to terrain obstacles (**very sensitive parameter**).

In order to estimate the mean wind speed u_2 at a height z_2 based on a known (measured) value u_1 at a height z_1 , the formula is rearranged as:

$$\frac{u_2}{u_1} = \ln\left(\frac{z_2}{z_0}\right) / \ln\left(\frac{z_1}{z_0}\right)$$

Wind turbine curves



2.1 Estimation of wind energy production

Estimation of energy production considering the wind velocity and wind turbine curve

=(IF(H11<=25;LOOKUP(H11;\$A\$11:\$A\$261;\$B\$11:\$B\$261);0))/1000 WindCalc sheet G N J С D Е F н K Α В Т L 1 ١ 1 ΔΕΔΟΜΕΝΑ 2 z0 = 0,02 ١ ١ z1 = 3 3 4 53 86 z2 = CF 0,30 0,33 5 Ετήσια Ενέργεια (MWh) 1312 2450 6 13121 24501 7 4,6 7,3 7,8 0,5 0,85 1 8 MWh MWh Wind turbine curves 9 500kW 3 53 86 850 kW 10 500 kW m/s 850 KW لک 11 1/10/2006 0:00 1,7 2,9 0,0 0 0 2,7 0,0 0 0 1 1/10/2006 1:00 2,0 3,1 3,3 12 0,1 0,1 0 0 0,0 0,0 0,2 1/10/2006 2:00 2,3 / 3,9 13 0,2 3,6 0 0 0,0 0,0 2,3 1/10/2006 3:00 14 0,3 0,3 3,7 3,9 0,0 0,0 0 0 1/10/2006 4:00 1,7 2,9 15 0,4 0 0,4 0 2,7 0,0 0,0 16 0,5 0,5 1/10/2006 5:00 1,6 2,5 2,6 0,0 0 0 0,0 0 0 1/10/2006 6:00 3.2 0.1 17 0.6 0.6 5.1 5.4 0.0

=G11*LN(\$B\$4/\$B\$2)/LN(\$B\$3/\$B\$2)

Estimation of wind velocity at the altitude of the wind turbine

2.2 Estimation of solar energy production





2.3 Energy balance in hourly basis

1	Α	В	С	D	E	F	G	Н	
1			turbine 1	turbine 2	Solar panels	Total installed			
2		Power kW	500	850	100	3600			
3		number	0	4	2				
4							Deficit	Surplus	
5	Energy MWh/y 6311,1		0,0	9800,6	344,0	10144,6	-2667,1	6500,6	
6	max hourly	2,72	0,00	3,40	0,20	3,60	-2,44	3,53	
7	mean hourly	0,72	0,00	1,12	0,04	1,16	-0,30	0,74	
8	minhourly	0,02	0,00	0,00	0,00	0,00			
9	Capacity factor	0,26	#DIV/0!	0,33	0,20	0,32			
10						Number ofdays	87672		
11						Number of Fails	47580		
12						Fails (%)	54,3		
13		Demand MWh	Production MWh						
14	Date		Turbines 1	Turbines 2	Solar panels	Total	Deficit	Surplus	
15	1/10/2006 0:00	0,66	0,60	0,00	7 0,00	0,00	7 -0,66	0	
16	1/10/2006 1:00	0,47	0,00	0,02	0,00	0,02	-0,45	0	
17	1/10/2006 2:00	0,47	0,00	0,07	0,00	0,07	-0,39	0	
18	1/10/2006 3:00	0,48	0.00	0,07	0,00	0,07	-0,40	0	
19	1/10/2006 4:00	0,44	0,00	0,00	0,00	0,00	-0,44	0	
20	1/10/2006 5:00	0,38	0,00	0,00	9,00	0,00	-0,38	0	
=windCalc!K11*\$C\$3' =C15+D15+E15 =windCalc!L11*\$D\$3' =IF(C15+D15+E15-B15<=0;C15+D15+E15-B15;0) / =SunCalc!C8*\$E\$3									
	=IF(C15+D15+E15-B15>=0;C15+D15+E15-B15;(

2.3 Energy balance in hourly basis

Demanc
6311,1
2,72
0,72
0,02
0,26

Hourly surplus-deficit using: **4*850 kW** wind turbines and **2*100 kW** panels



	Deficit	Surplus
Energy MWh/y	-2667,1	6500,6
Max hourly (kW)	-2,44	3,53
Mean hourly (kW)	-0,30	0,74
Hourly fails (%)	54,3	

2.3 Energy balance on an hourly basis



Annual surplus-deficit using various combinations

3. Covering energy deficits using other sources

Oil-Biomass

	G	Н	1	J	K	L	=SUM(J15:J87686)/10
1					Oil	Biomass	
2				Calorific (kWh/kg)	12	4	
3				efiiciency (%)	40	40	A P P
4	Deficit	Surplus	Check	MWh/tn	4,8	1,6	
5	-2667,1	6500,6	0,0			1	
6	-2,44	3,53			K		
7	-0,30	0,74		tn/y	556	1667	
8				I (MW)	7 2,44	2,44	
9				CF	0,12	0,12	
10	87672			=-G6	K		
11	47580						~~~=G5/(G6*8760)
12	54,3			To cover deficit			
13				Oil (tn)	Biomass (tr	1)	
14	Deficit	Surplus					
15	-0,66	0		0,137	0,411	7	
16	-0,45	0		0,094	0,283		
17	-0,39	0		0,082	0,247		
18	-0,40	0		0,084	0,252		
19	-0,44	0		0,092	0,275	=]	F(G15<0;-G15/\$L\$4;0)
20	-0,38	0		0,078	0,235		
21	-0,12	0		0,025	0,076		
22	-0,38	0		0,079	0,237		
23	-0,37	0	· · · ·	0,078	0,234		
24	-0,28	0		0,057	0,172		

=IF(G15<0;-G15/\$K\$4;0)

4. Energy storage using hydropower



3-4. Covering energy deficits using other sources



