


Postgraduate program: Environment and Development Course: Energy and Environment



National Technical
University of Athens

Exercise instructions: Design of Small Hydroelectric Power Plants



Nikos Mamassis, Andreas Efstratiadis,
Department of Water Resources & Environmental Engineering,
School of Civil Engineering, NTUA

Exercise

The construction of a small hydropower plant with a net head of 260 m is considered in a specific river location. Daily flow data are available at the location of the intake for a period of 10 hydrologic years (Excel file), whereas Table 1 contains the corresponding values of the mean monthly flows.

Table 1 Mean Monthly Flows (m³/s)

Month	10	11	12	1	2	3	4	5	6	7	8	9	Annual
Mean value	0.48	1.37	1.46	0.99	1.40	1.53	1.66	1.03	0.42	0.23	0.15	0.12	0.90

Requested:

1. The estimation of the environmental flow and the timeseries of the daily volume of water exploitable for hydropower production
2. The initial estimation of the mean annual potential electrical energy, assuming a total efficiency of 0.85
3. The development of the exploitable daily flow duration curve
4. The development of a spreadsheet for the simulation of the hydropower plant's daily operation and the calculation of the electricity produced. Assume that the turbine starts operating with a flow higher than 10% of the maximum flow and has a **constant total efficiency** of 0.85. Considering that one turbine is going to be installed, estimate its nominal flow, so that the production of electrical energy is maximised.
5. The development of a spreadsheet for the simulation of the hydropower plant's daily operation and the calculation of the electricity produced. Assume that the turbine has a **variable efficiency** (that can be estimated via the curves supplied), whereas the efficiency of the electromechanical equipment is 0.96. Considering that one turbine is going to be installed, estimate its nominal flow, so that the production of electrical energy is maximised. Use the performance curves of the three turbine types (Francis, Pelton, Kaplan), which are supplied in the Excel file. Assume that the following conditions will need to apply: a) the volume of water utilised, after the deduction of the environmental flow, needs to be at least 75% of the total, and b) the exploitation index of the plant needs to be at least 30%
6. Investigate the installation of two turbines. Calculate the electrical energy produced from different turbine combinations and identify the most efficient ones in terms of electricity production
7. The final selection of **two** turbines, after taking into account other factors besides the maximisation of electrical energy production

1. Environmental flow estimation

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1															
2	Έκταση	42.8	km2												
3	Απορροή	28.4	hm3												
4	Απορροή	663.3	mm												
5															
6															
7		10	11	12	1	2	3	4	5	6	7	8	9	Έτος	
8	1971-72	0.18	0.77	1.32	1.02	1.73	1.78	1.55	1.00	0.31	0.21	0.13	0.08	0.84	
9	1972-73	1.20	1.17	0.59	1.43	2.61	2.14	1.74	0.91	0.28	0.11	0.05	0.09	1.03	
10	1973-74	0.32	0.81	1.13	0.20	1.89	1.71	2.17	1.57	0.42	0.11	0.07	0.17	0.88	
11	1974-75	0.90	2.81	1.57	0.76	1.54	1.92	1.06	0.67	0.43	0.15	0.15	0.09	1.00	
12	1975-76	0.77	3.45	2.22	1.11	0.44	2.45	3.62	2.18	0.76	0.22	0.12	0.12	1.45	
13	1976-77	0.22	0.94	1.99	1.05	0.87	1.45	0.99	0.42	0.49	0.32	0.11	0.08	0.74	
14	1977-78	0.18	1.19	0.89	1.80	1.95	1.40	0.98	0.72	0.39	0.40	0.14	0.11	0.85	
15	1978-79	0.57	0.63	0.82	0.39	0.53	0.31	1.28	0.26	0.16	0.09	0.26	0.10	0.45	
16	1979-80	0.15	0.80	3.67	1.88	2.13	1.49	1.37	1.32	0.42	0.48	0.41	0.30	1.20	
17	1980-81	0.28	1.16	0.40	0.28	0.34	0.61	1.80	1.28	0.57	0.18	0.10	0.05	0.59	
18	Μέση τιμή	0.48	1.37	1.46	0.99	1.40	1.53	1.66	1.03	0.42	0.23	0.15	0.12	0.90	
19															
20	ΟΙΚΟΛΟΓΙΚΗ 1		0.08												
21	ΟΙΚΟΛΟΓΙΚΗ 2		0.06												
22	ΟΙΚΟΛΟΓΙΚΗ 3		0.03												
23															
24	ΟΙΚΟΛΟΓΙΚΗ		0.08												
25	V hm3		25.9												
26	75%*V		19.4												
27															
28		0.90	0.08	0.82											
29			ΟΙΚΟΛΟΓΙΚΗ	ΕΚΜΕΤΑΛΛΕΥΣΗ				ΚΑΜΠΥΛΗ ΔΙΑΡΚΕΙΑΣ							
30	1/10/1971	0.17	0.08	0.09				ΣΥΧΝΟΤΗΤΑ	ΕΚΜΕΤΑΛΛΕΥΣΗ						
31	2/10/1971	0.17	0.08	0.09				1	0.03	12.10					
32	3/10/1971	0.17	0.08	0.09				2	0.05	10.56					
33	4/10/1971	0.17	0.08	0.09				3	0.08	10.32					
34	5/10/1971	0.15	0.08	0.07				4	0.11	9.31					
35		0.12	0.08	0.04				5	0.14	7.81					

Estimation of environmental flow as the maximum of:

1. 30% of the mean discharge of summer months (June, July, August) or
2. 50% of the mean discharge of September or
3. 30 lt/sec in any case.

Flow duration curve

1. Ranking daily discharges in descending order
2. Calculation of empirical probability of exceedance

SB1


Slide 3

SB1

"Flow duration curve" instead of "duration curve" or "Flow duration curve for hydropower production"

Sandra Baki, 28-Mar-19

2. Initial estimations



Mean discharge available for hydropower exploitation: **0.82 m/s** (the environmental flow has been abstracted)

Mean annual water volume available for hydropower exploitation: **25.9 hm³**

Assuming:

ρ 1000 kg/m³

g 9.81 m/s²

H 260 m

n 0.85

Potential values assuming complete exploitation:

Mean annual energy produced: **15 624 MWh**

Installed power for continuous operation: **1.8 MW**

Installed power for operation of 3000 h: **5.2 MW**

2. Initial estimations

Mean discharge available for exploitation: **0.82 m/s**

Mean annual water volume available for exploitation: **25.9 hm³**

$$\rho \quad 1000 \text{ kg/m}^3$$

$$g \quad 9.81 \text{ m/s}^2$$


$$H \quad 260 \text{ m}$$

$$n \quad 0.85$$


Discharge–installed power relationship

$Q \text{ (m}^3/\text{s)}$	$I \text{ (MW)}$
0.5	1.1
1	2.2
1.5	3.3
2	4.3
2.5	5.4
3	6.5
4	8.7
5	10.8
10	21.7



Volume percentage–discharge relationship



Volume–time percentage relationship



3. Daily flow duration curve



4. Examples with 1 turbine ($n=0.85$, $Q_{min}=0.2*Q_{max}$)

Theoretical power for various discharges

Warning: In exercise $Q_{min}=0.1*Q_{max}$

Data

	Q (m ³ /s)	I (MW)
H=260 m	0.5	1.1
$\rho=1000$ kg/m ³	1	2.2
$g=9.81$ m/s ²	1.5	3.3
$n=0.85$	2	4.3
	2.5	5.4
	3	6.5
	4	8.7
	5	10.8
	10	21.7

Legend

Q_{min}, Q_{max}:



Minimum, maximum exploitation discharge (m³/s)

I_{max}: Power at maximum exploitation discharge (MW)

PT : Percentage of operational time in a typical year (%)

PV: Percentage of water volume used (%)

E: Total annual electrical energy produced (GWh/y)



4. Calculations for 1 turbine

Data-
Constants

	A	B	C	D	E	F	G	H	I
1									
2									
3									
4	H	260		For 10 years	m ³ /s	m ³ /day	kWh	kW	
5	ρ	1000		Maximum	12.1	1045256.9	629479.8	26228.3	
6	g	9.81		Minimum	0	0	0	0	
7	n	0.85		Mean	0.822	71029.3	42775.6	1782.3	
8									
9						hm ³	GWh		
10				Total		259.5	156.3		
11				Total days	3653				
12				Mean annual		25.9	15.6		
13									
14									
15									
16	Max-Min exploitation discharge (m³/s)					Qmax (m3/s)	10	5	2
17						Qmin (m3/s)	1	0.5	0.2
18	Power at max exploitation discharge (MW)					Imax (MW)	21.7	10.8	4.3
19	Percentage of operational time per year (%)					PT (%)	29.9	44.7	61.7
20	Percentage of water volume used (%)					PV (%)	76.9	88.6	80.6
21	Total electrical energy (GWh)					E (GWh)	120.2	138.4	126.0
22						E (GWh/y)	12.0	13.8	12.6
23						ΣΔ	0.06	0.15	0.33
24		m3/s	m3/day	kWh	kW		kWh/d	kWh/d	kWh/d
25	1/10/1971	0.094	8153.6	4910.3	204.6		0	0	0
26	2/10/1971	0.094	8153.6	4910.3	204.6		0	0	0
27	3/10/1971	0.094	8153.6	4910.3	204.6		0	0	0
28	4/10/1971	0.069	5941.2	3577.9	149.1		0	0	0

Daily timeseries statistics (a) discharge, (b) water volume, (c) potential energy and (d) required power

Daily electrical energy E(kWh)=g*n*H(m)*V(m³)/3600

=B\$6*B\$7*B\$4*C25/3600

Data-
daily
discharge
timeseries

Daily volume (m³)

=B25*86400

=D25/24

Daily power I(kW)=E(kWh)/24h

4. Calculations for 1 turbine

	A	B	C	D	E	F	G	H	I
1									
2									
3									
4	H	260							
5	ρ	1000							
6	g	9.81							
7	n	0.85							
8									
9									
10									
11									

- If the daily discharge is within the operational range (minimum-maximum discharge), then the **daily energy** is calculated using the formula

$$E(\text{kWh}) = g \cdot n \cdot H(\text{m}) \cdot V(\text{m}^3) / 3600 = g \cdot n \cdot H(\text{m}) \cdot Q(\text{m}^3/\text{s}) \cdot 86400 / 3600 = g \cdot n \cdot H(\text{m}) \cdot Q(\text{m}^3/\text{s}) \cdot 24$$
- If the daily discharge is greater than the nominal (maximum) one, then the **daily energy** is calculated with a discharge equal to the nominal one.
- If the daily discharge is lower than the minimum operational, then the **daily energy is equal to zero**

=IF(AND(\$B25>G\$17,\$B25<G\$16),\$B\$4*\$B\$6*\$B\$7*\$B25*24,IF(\$B25>G\$16,\$B\$4*\$B\$6*\$B\$7*G\$16*24,0))

Min and max operational discharge are defined by the user

16	Max-Min exploitation discharge (m³/s)				Qmax (m ³ /s)	10	5	2
17					Qmin (m ³ /s)	1	0.5	0.2
18	Power at max exploitation discharge (MW)				lmax (MW)	21.7	10.8	4.3
19	Percentage of operational time per year (%)				PT (%)	29.9	44.7	61.7
20	Percentage of water volume used (%)				PV (%)	76.9	88.6	80.6
21	Total electrical energy (GWh)				E (GWh)	120.2	138.4	126.0
22					E (GWh/y)	12.0	13.8	12.6
23					ΣΔ	0.06	0.15	0.33
24		m ³ /s	m ³ /day	kWh	kW	kWh/d	kWh/d	kWh/d
25	1/10/1971	0.094	8153.6	4910.3	204.6	0	0	0
26	2/10/1971	0.094	8153.6	4910.3	204.6	0	0	0
27	3/10/1971	0.094	8153.6	4910.3	204.6	0	0	0
28	4/10/1971	0.069	5941.2	3577.9	149.1	0	0	0

4. Calculations for 1 turbine

	A	B	C	D	E	F	G	H	I
1									
2									
3									
4	H	260							
5	ρ	1000							
6	g	9.81							
7	n	0.85							
8									

Calculation of the water volume percentage exploited

- The energy produced is summed
- The daily water volume is calculated (and summed for the entire time period) using the formula: $V(m^3)=Q (m^3/s)*t (hr)*3600=E(kWh)/[g*n*H(m)]=>$
 $V(m^3)=E(kWh)/[g*n*H(m)*3600]$
- This is divided by the total water volume and the percentage is calculated

$$=(SUM(G25:G3677)*3600/(B4*B6*B7))/(F10*1000000)*100$$

			hm ³	GWh
10	ΑΘΡΟΙΣΜΑ		259.5	
11	Total number of days	3653		
12	Mean annual		25.9	


Calculation of the operational time in the year

The days in which energy was produced are counted and the percentage is calculated considering the total number of days

$$=COUNTIF(G25:G3677,">0")/E11*100$$

16	Max-Min exploitation discharge (m³/s)				Qmax (m3/s)	10	5	2
17					Qmin (m3/s)	1	0.5	0.2
18	Power at max exploitation discharge (MW)				Imax (MW)	21.7	10.8	4.3
19	Percentage of operational time per year (%)				PT (%)	29.9	44.7	61.7
20	Percentage of water volume used (%)				PV (%)	76.9	88.6	80.6
21	Total electrical energy (GWh)				E (GWh)	120.2	138.4	126.0
22					E (GWh/y)	12.0	13.8	12.6
23					ΣΔ	0.06	0.15	0.33
24		m3/s	m3/day	kWh	kW		kWh/d	kWh/d
25	1/10/1971	0.094	8153.6	4910.3	204.6		0	0
26	2/10/1971	0.094	8153.6	4910.3	204.6		0	0
27	3/10/1971	0.094	8153.6	4910.3	204.6		0	0
28	4/10/1971	0.069	5941.2	3577.9	149.1		0	0

4. Examples with 1 turbine (n=0.85, Qmin=0.1*Qmax)



Nominal discharge range, for which the percentage of operational time is greater than 30%

Nominal operational discharge for maximization of the produced energy (use of solver)

13							
14							
15							
16	Qmax (m3/s)	10	5	2	0,449		
17	Qmin (m3/s)	1	0,5	0,2	0,449		
18	Imax (MW)	21,7	10,8	4,3	9,7		
19	PT (%)	29,9	44,7	61,7	46,6		
20	PV (%)	76,9	88,6	80,6	89,0		
21	E (GWh)	120,2	198,4	126,7	139,1		
22	E (GWh/y)	12,0	13,8	12,6	13,9		
23	ΣΔ	0,06	0,15	0,33	0,16		
24		kWh/d	kWh/d	kWh/d	kWh/d		
25		0	0	0	0		
26		0	0	0	0		
27		0	0	0	0		
28		0	0	0	0		
29		0	0	0	0		
30		0	0	0	0		
31		0	0	0	0		
32		0	0	0	0		
33		0	0	0	0		
34		0	0	0	0		
35		0	0	0	0		
36		0	0	0	0		
37		0	0	0	0		
38		0	0	0	0		
39		0	0	0	0		
40		0	0	0	0		
41		0	0	0	0		
42		0	0	11064,634	0		
43		0	0	0	0		
44		0	0	0	0		
45		0	0	0	0		

Βελτιστοποίηση με 1 στροβίλο
Qmin=0.1*Qmax
4,49

Q=4.49 m³/s
E=13.9 GWh/y

Solver Parameters

Set Objective: \$J\$21

To: Max Min Value Of: 0

By Changing Variable Cells: \$J\$16


Subject to the Constraints:

Make Unconstrained Variables Non-Negative

Select a Solving Method: GRG Nonlinear


Solving Method: Select the GRG Nonlinear engine for Solver Problems that are smooth nonlinear. Select the LP Simplex engine for linear Solver Problems, and select the Evolutionary engine for Solver problems that are non-smooth.

Buttons: Help, Solve, Close



Nominal discharge range, for which the percentage of water volume used is greater than 75%


Energy production curve for nominal discharge in the range 1-12 m³/s



5. Turbine efficiency curves

- Assuming an efficiency for the electromechanical equipment of **0.96**,
- the total efficiency of **0.85** corresponds to:
- a turbine efficiency of $0.85/0.96=$ **0.885**

Q/Qmax	Francis ns=100	Pelton ns=21	Kaplan ns=650
10	0,3	0,78	0,08
20	0,6	0,86	0,78
30	0,77	0,88	0,87
40	0,82	0,89	0,91
50	0,85	0,89	0,93
60	0,88	0,89	0,94
70	0,91	0,89	0,94
80	0,93	0,89	0,94
90	0,94	0,89	0,94
100	0,93	0,89	0,93



	Francis ns=100	Pelton ns=21	Kaplan ns=650
0	0	0	0
1	1	1	1
2	2	2	2
3	3	3	3
4	4	4	4
5	5	5	5
6	6	6	6
7	7	7	7
8	8	8	8
9	9	9	9
10	0,3	0,78	0,08
11	0,33	0,788	0,15
12	0,36	0,796	0,22
13	0,39	0,804	0,29
14	0,42	0,812	0,36
15	0,45	0,82	0,43
16	0,48	0,828	0,5
17	0,51	0,836	0,57
18	0,54	0,844	0,64
19	0,57	0,852	0,71
20	0,6	0,86	0,78
21	0,617	0,862	0,789
22	0,634	0,864	0,798
23	0,651	0,866	0,807
24	0,668	0,868	0,816
25	0,685	0,87	0,825
26	0,702	0,872	0,834
27	0,719	0,874	0,843
28	0,736	0,876	0,852
29	0,753	0,878	0,861
30	0,77	0,88	0,87
31	0,775	0,881	0,874
32	0,78	0,882	0,878
33	0,785	0,883	0,882
34	0,79	0,884	0,886
35	0,795	0,885	0,89
36	0,8	0,886	0,894
37	0,805	0,887	0,898
38	0,81	0,888	0,902
39	0,815	0,889	0,906
40	0,82	0,89	0,91
41	0,823	0,89	0,912
42	0,826	0,89	0,914
43	0,829	0,89	0,916
44	0,832	0,89	0,918
45	0,835	0,89	0,92
46	0,838	0,89	0,922
47	0,841	0,89	0,924
48	0,844	0,89	0,926
49	0,847	0,89	0,928
50	0,85	0,89	0,93
51	0,853	0,89	0,931
52	0,856	0,89	0,932
53	0,859	0,89	0,933
54	0,862	0,89	0,934
55	0,865	0,89	0,935
56	0,868	0,89	0,936
57	0,871	0,89	0,937
58	0,874	0,89	0,938
59	0,877	0,89	0,939
60	0,88	0,89	0,94
61	0,883	0,89	0,94
62	0,886	0,89	0,94
63	0,889	0,89	0,94
64	0,892	0,89	0,94
65	0,895	0,89	0,94
66	0,898	0,89	0,94
67	0,901	0,89	0,94
68	0,904	0,89	0,94
69	0,907	0,89	0,94
70	0,91	0,89	0,94
71	0,912	0,89	0,94
72	0,914	0,89	0,94
73	0,916	0,89	0,94
74	0,918	0,89	0,94
75	0,92	0,89	0,94
76	0,922	0,89	0,94
77	0,924	0,89	0,94
78	0,926	0,89	0,94
79	0,928	0,89	0,94
80	0,93	0,89	0,94
81	0,931	0,89	0,94
82	0,932	0,89	0,94
83	0,933	0,89	0,94
84	0,934	0,89	0,94
85	0,935	0,89	0,94
86	0,936	0,89	0,94
87	0,937	0,89	0,94
88	0,938	0,89	0,94
89	0,939	0,89	0,94
90	0,94	0,89	0,94
91	0,939	0,89	0,939
92	0,938	0,89	0,938
93	0,937	0,89	0,937
94	0,936	0,89	0,936
95	0,935	0,89	0,935
96	0,934	0,89	0,934
97	0,933	0,89	0,933
98	0,932	0,89	0,932
99	0,931	0,89	0,931
100	0,93	0,89	0,93

5. Example with 1 turbine (with efficiency curve)

	A	B	C	D	E	F	G	H	I	J
1	H	260		$I \text{ (kW)} = 9.81 * Q \text{ (m}^3/\text{s)} * H \text{ (m)} * n$					Turbine efficiency curve	
2	p	1000							Francis ns=100	
3	g	9,81							Q/Qmax	n
4	n	0,96	Efficiency of the electromechanical equipment						0	
5									1	
6									2	
7									3	
8									4	
9									5	
10									6	
11									7	
12									8	
13									9	
14									10	0,3
15									11	0,33
16									12	0,36
17	Max-Min exploitation discharge (m³/s)				Francis ns=100				13	0,39
18					Qmax (m ³ /s)	3,00			14	0,42
19	Power at max exploitation discharge				Qmin (m ³ /s)	0,30			15	0,45
20	Percentage of operational time per year				Imax (MW)	7,3			16	0,48
21	Percentage of water volume used				PT (%)	53,4			17	0,51
22	Total electrical energy (GWh)				PV (%)	87,3			18	0,54
23					E (GWh)	128,5			19	0,57
24					E (GWh/y)	12,9			20	0,6
25					ΣΔ	0,20			21	0,617
26		m ³ /s	m ³ /day		kWh/d	Q/Qmx	Efficiency	kWh/d	22	0,634
99	12/12/1971	0,620	53561,1		36430,1	20	0,60	21858,1	95	0,935
100	13/12/1971	0,708	61146,6		41589,5	23	0,65	27074,7	96	0,934
101	14/12/1971	0,794	68626,7		46677,1	26	0,70	32767,4	97	0,933
102	15/12/1971	0,860	74315,8		50546,6	28	0,74	37202,3	98	0,932

WARNING: The calculation of the percentage of the used water volume changes. Initially, the efficiency of the turbines is calculated as the quotient of the final energy to the initial energy that was calculated by taking into account the efficiency of the electromechanical equipment.

$$\frac{\text{SUM}(H27:H3679)}{\text{SUM}(E27:E3679)}$$

The new formula incorporates the efficiency of the turbines

$$\frac{(\text{SUM}(H27:H3679)*3600)/(\$B\$1*\$B\$3*\$B\$4*\text{SUM}(H27:H3679)/\text{SUM}(E27:E3679))}{(\$C\$12*1000000)*100}$$


1. The energy is calculated by taking into account the efficiency of the electromechanical equipment. It will later be corrected with the efficiency of the turbines that corresponds to the daily discharge by taking into account the turbine efficiency curves

2. The percentage of the daily discharge to the nominal one, is calculated


3. According to the percentage of the daily discharge to the nominal one, the corresponding efficiency is located in the efficiency curve

4. The daily energy is corrected according to the turbine efficiency

5. Example with 1 turbine (with efficiency)




Nominal discharge range, for which the percentage of operational time is greater than 30%



Nominal discharge range, for which the percentage of water volume used is greater than 75%

Energy production curve for nominal discharge in the range 1-12 m^3/s



Constant efficiency $n=0.85$

$Q=4.4 \text{ m}^3/\text{s}$ $E=13.9 \text{ GWh/y}$

Pelton

$Q=4.2 \text{ m}^3/\text{s}$ $E=13.8 \text{ GWh/y}$

Kaplan

$Q=3.4 \text{ m}^3/\text{s}$ $E=13.6 \text{ GWh/y}$

Francis



$Q=3.0 \text{ m}^3/\text{s}$ $E=12.8 \text{ GWh/y}$

6. Examples with 2 turbines ($n=0.85$, $Q_{min}=0.2*Q_{max}$)

Warning: In exercise $Q_{min}=0.1*Q_{max}$

Data

	Theoretical power for various discharges	
	Q (m ³ /s)	I (MW)
H=260 m	0.5	1.1
$\rho=1000$ kg/m ³	1	2.2
$g=9.81$ m/s ²	1.5	3.3
$n=0.85$	2	4.3
	2.5	5.4
	3	6.5
	4	8.7
	5	10.8
	10	21.7



Legend

Q_{min} , Q_{max} :

Minimum, maximum exploitation discharge (m³/s)

I_{max} : Power at maximum exploitation discharge (MW)

PT : Percentage of operational time in a typical year (%)

PV: Percentage of water volume used (%)

E: Total annual electrical energy produced (GWh/y)

6. Examples with 2 turbines ($n=0.85$, $Q_{min}=0.2*Q_{max}$)


Warning: In exercise $Q_{min}=0.1*Q_{max}$

Data

H=260 m
 $\rho=1000 \text{ kg/m}^3$
 $g=9.81 \text{ m/s}^2$
 $n=0.85$

Theoretical power for various discharges

Q (m ³ /s)	I (MW)
0.5	1.1
1	2.2
1.5	3.3
2	4.3
2.5	5.4
3	6.5
4	8.7
5	10.8
10	21.7



Legend

Q_{min} , Q_{max} :


Minimum, maximum exploitation discharge (m³/s)

I_{max} : Power at maximum exploitation discharge (MW)

PT : Percentage of operational time in a typical year (%)

PV: Percentage of water volume used (%)

E: Total annual electrical energy produced (GWh/y)



6. Optimization with 2 turbines ($n=0.85$ for $Q_{\min}=0.1*Q_{\max}$)

	Optimization with 1 turbine	Optimization with 2 same turbines	Optimization with 2 sequential turbines
	$Q_{1\min}=0.1*Q_{1\max}$	$Q_{1\min}=0.1*(Q_{2\max}/2)$	$Q_{1\min}=0.1*0.1*Q_{2\max}$
Q_{\max} (m ³ /s)	4,49	5,08	8,71 = $Q_{1\max}+Q_{2\max}$
Q_{\min} (m ³ /s)	0,45	0,25	0,09 = $Q_{1\min}$
I_{\max} (MW)	9,7	11,0	18,9 (16.9 and 2 MW)
PT (%)	46,6	56,4	75,8
PV (%)	89,0	93,8	99,0
E (GWh)	139,1	146,6	154,7
E (GWh/y)	13,9	14,7	15,5
$\Sigma\Delta$	0,16	0,15	0,09

Theoretical power for various discharges

DATA

$H=260$ m
 $\rho=1000$ kg/m³
 $g=9.81$ m/s²
 $n=0.85$

Q (m ³ /s)	I (MW)
0.5	1.1
1	2.2
1.5	3.3
2	4.3
2.5	5.4
3	6.5
4	8.7
5	10.8
10	21.7

6. Optimization with 2 turbines (considering efficiency curves)

We make the assumption, that initially the first turbine starts operating and in the case that the discharge is out of its operational range, then the flow is routed to the second turbine

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	H	260																
2	ρ	1000					Καμπύλη 1		Καμπύλη 2									
3	g	9,81					Q/Qmax	n	Q/Qmax	n								
4	n	0,96	ΣΑ Ηλεκτρομηχανολογικού εξοπλισμού				0		0									
5							1		1									
6	Για 10 έτη	m3/s					2		2									
7	ΜΕΓΙΣΤΟ	12,1					3		3									
8	ΕΛΑΧΙΣΤΟ	0					4		4									
9	ΜΕΣΟ	0,822					5		5									
10							6		6									
11			hm3				7		7				Σύνολο					
12	ΑΘΡΟΙΣΜΑ	259,5		229,2	30,3	19,9	8		8				Qmax (m3/s)	3,80				
13	Σύνολο ημερών	3653					9		9				Qmin (m3/s)	0,04				
14							10	0,3	10	0,3			E (GWh/y)	13,9				
15	Μέσο ετήσιο	25,9					11	0,33	11	0,33								
16			Στρόβιλος 1		Στρόβιλος 2		12	0,36	12	0,36			Στρόβιλος 1				Στρόβιλος 2	
17			Qmax (m3/s)	3,40	0,40		13	0,39	13	0,39			Qmax (m3/s)	3,40			0,40	
18			Qmin (m3/s)	0,34	0,04		14	0,42	14	0,42			Qmin (m3/s)	0,34			0,04	
19							15	0,45	15	0,45			E (GWh)	12,8			1,1	
20							16	0,48	16	0,48								
21							17	0,51	17	0,51								
22							18	0,54	18	0,54								
23							19	0,57	19	0,57								
24							20	0,6	20	0,6								
25			Παροχές Σ1	Υπόλοιπο	Παροχές Σ2		21	0,617	21	0,617								
26		m3/s	m3/s	m3/s	m3/s		22	0,634	22	0,634			kWh/d	Q/Qmx	ΣΑ	kWh/d	kWh/d	Q/Qmx
27	1/10/1971	0,094	0,000	0,094	0,094		23	0,651	23	0,651			0,0	1	0,00	0,0	5545,8	23
28	2/10/1971	0,094	0,000	0,094	0,094		24	0,668	24	0,668			0,0	1	0,00	0,0	6545,8	23
29	3/10/1971	0,094	0,000	0,094	0,094		25	0,685	25	0,685			0,0	1	0,00	0,0	5545,8	23

=B27-D27

=\$B\$1*\$B\$3*\$B\$4*\$D27*24

Allocation of discharge to 2 turbines

=IF(AND(\$E27>F\$18;\$E27<F\$17);\$E27;IF(\$E27>F\$17;F\$17;0))

=IF(AND(\$B27>D\$18;\$B27<D\$17);\$B27;IF(\$B27>D\$17;D\$17;0))

=\$B\$1*\$B\$3*\$B\$4*\$F27*24

7. Optimization with 2 turbines (considering efficiency curves)

We make the assumption, that initially the first turbine starts operating and in the case that the discharge is out of its operational range, then the flow is routed to the second turbine

2 Pelton turbines

Qmax (m³/s)	4,2	4,2		4,2		4,2	
E (GWh/y)	13,8	14,6		14,9		15,1	
		Σ1	Σ2	Σ1	Σ2	Σ1	Σ2
Q_{1,2}max (m³/s)		2,1	2,1	3,0	1,2	3,8	0,4
E_{1,2} (GWh/y)		12,7	1,8	13,6	1,3	13,8	1,3

2 Francis turbines

Qmax (m³/s)	3,0	3,0		3,0		3,0	
E (GWh/y)	12,9	14,2		14,0		13,9	
		Σ1	Σ2	Σ1	Σ2	Σ1	Σ2
Q_{1,2}max (m³/s)		1,5	1,5	2,0	1,0	2,7	0,3
E_{1,2} (GWh/y)		11,2	3,0	12,3	1,7	12,8	1,0

Pelton-Francis Combination

Qmax (m³/s)	3,0		3,0		3,0		3,0		3,0		3,0	
E (GWh/y)	14,3		14,1		14,2		14,1		14,4		14,0	
	Pelton	Francis	Francis	Pelton	Pelton	Francis	Francis	Pelton	Pelton	Francis	Francis	Pelton
Q_{1,2}max (m³/s)	1,5	1,5	1,5	1,5	2,0	1,0	2,0	1,0	2,5	0,5	2,5	0,5
E_{1,2} (GWh/y)	11,4	3,0	11,2	2,9	12,6	1,7	12,3	1,7	13,2	1,1	12,7	1,2